

# TEST CERTIFICATE

## to anti-slip property of floor- and ramp surfaces and to skid resistance of surfaces of swimming pool equipment

Tested material: **Plastic material**

Kind of material: PVC-P covering  
Article description: ISLAND DREAMS **Ibiza/Capri/Tahiti/Fiji**  
Dimensions: length and width variable, thickness: 1,9 mm  
Colour: according to manufacturer instruction different colours  
are deliverable; colour description of the test specimen:  
sand, No. 153

Surface: embossed, embossment 12 with fleece beneath  
Addition: with fleece coat beneath

Producer/supplier: ELBTAL PLASTICS GmbH & Co. KG  
Grenzstraße 9  
01640 Coswig  
GERMANY

Client: ELBTAL PLASTICS GmbH & Co. KG  
Grenzstraße 9  
01640 Coswig  
GERMANY

Certificate number: 85021801.001e  
(tested under 74401605.002)

Test date: 01.03.2016

Sampling: Sent by the customer to the research institute

Test method: **DIN EN 13451**, ed. 2011-11 „Swimming pool equipment“  
Part 1: „General safety requirements and test methods“  
Part 2: „Additional specific safety requirements and test methods for ladders,  
stepladders and handle bends“ (ed. 2001-07)  
Part 4: „Additional specific safety requirements and test methods for starting  
platforms“ (ed. 2001-07)

**DIN EN 15288-1**, ed. 2010-12 „Swimming pools“  
Part 1: „Safety requirements for design“

Delivery of the test material has been effected in ready-to-test surface condition.

Test result: Average inclination angle: **27°**  
(degree of inclination)

Assessment: **Evaluation category of slip resistance: 24°**

**SÄUREFLIESNER-VEREINIGUNG E. V.**  
Institut für Wand- und Bodenbeläge  
Managing Director

  
Dipl.-Ing. Friedrich Höltekemeyer



Großburgwedel, 02.11.2018  
Schu/ed-pp

This test-certificate is valid as long as there is no change in the above mentioned test-basis - for products which are identical to the test-specimen. The certificate is given for 5 years (starting from test date).  
The publication and reproduction of this report is only allowed in unabridged form.



– Institut für Wand- und Bodenbeläge –

**SÄUREFLIESNER-VEREINIGUNG E.V.**



Im Langen Felde 4, 30938 Burgwedel · Telefon (051 39) 99 82-0 · Telefax (051 39) 99 82-40 · E-Mail: info@saeurefliesner.de

Anerkannte Prüf-, Zertifizierungs- und Überwachungsstelle d. DIBt und DIN CERTCO, Berlin · Notifizierte Prüfstelle der Kommission der EU, Brüssel, Kenn-Nr. 1212